



HM-600/700/800

The best daisy-chain microinverter with reactive power control for 2 solar panels

Highlights

- Easy installation, just plug and play
- External antenna for stronger communication with DTU
- Power factor (adjustable) 0.8 leading.....0.8 lagging
- High reliability; NEMA (IP67) enclosure; 6000V surge protection



Safer



Smarter



More Powerful



More Reliable

Model	HM-600	HM-700	HM-800
-------	--------	--------	--------

Input Data (DC)

Commonly used module power (W)	240~380	280~440	320~500
Module compatibility	60-cell or 72-cell PV modules	60-cell or 72-cell PV modules	60-cell or 72-cell PV modules
Peak power MPPT voltage range (V)	29~48	33~48	34~48
Start-up voltage (V)	22	22	22
Operating voltage range (V)	16~60	16~60	16~60
Maximum input voltage (V)	60	60	60
Maximum input current (A)	2*11.5	2*11.5	2*12.5

Output Data (AC)

Rated output power (VA)	600	700	800
Rated output current(A)	2.73 / 2.61 / 2.5	3.18 / 3.04 / 2.92	3.64 / 3.48 / 3.33
Nominal output voltage (V)	220 / 230 / 240	220 / 230 / 240	220 / 230 / 240
Nominal output voltage range (V)	180-275 ¹	180-275 ¹	180-275 ¹
Nominal frequency/range (Hz)	60/55-65 ¹	60/55-65 ¹	60/55-65 ¹
Power factor (adjustable)	>0.99 default 0.8 leading...0.8 lagging	>0.99 default 0.8 leading...0.8 lagging	>0.99 default 0.8 leading...0.8 lagging
Total harmonic distortion	<3%	<3%	<3%
Maximum units per branch ²	8 / 8 / 8	7 / 7 / 7	6 / 6 / 6

Efficiency

CEC peak efficiency	96.70%	96.70%	96.70%
CEC weighted efficiency	96.50%	96.50%	96.50%
Nominal MPPT efficiency	99.80%	99.80%	99.80%
Nighttime power consumption (mW)	<50	<50	<50

Mechanical Data

Ambient temperature range (°C)	-40~+65
Dimensions (W×H×D mm)	250 x 170 x 28
Weight (kg)	3.0
Enclosure rating	Outdoor-NEMA (IP67)
Cooling	Natural convection – No fans

Features

Communication	2.4GHz Proprietary RF(Nordic)
Monitoring	Hoymiles Monitoring System
Warranty	Up to 25 years
Compliance	UL1741, IEEE1547, CSA C22.2 No. 107.1-16, NOM-001-SCFI-1993, FCC Part15, ANSI C63.4, ICES-003, ABNT NBR 16149:2013, ABNT NBR 16150:2013, Anatel

*1 Nominal voltage/frequency range can be changed due to the requirements of local power department.

*2 Refer to local requirements for exact number of microinverters per branch.